

GOVERNMENT OF TRIPURA
OFFICE OF THE ASSISTANT ENGINEER
PWD (DWS) SUB-DIVISION, SONAMURA
SEPAHIJALA, TRIPURA.

TO WHOME IT MAY CONCERN

This is to certify that drinking water facilities of Boxanagar H.S School under Boxanagar RD Block of Sepahijala District is completely safe for drinking water as per water testing report issued by the office of the undersigned.



Assistant Engineer
PWD (DWS), Sub-Division Sonamura
Sepahijala Tripura

GOVERNMENT OF TRIPURA
DWS LABORATORY AT TREATMENT PLANT AT SONAMURA
UNDER DWS SUB-DIVISION
SONAMURA, SEPAHIJALA TRIPURA

Dated, Sonamura, the 13th July, 2026

REPORT ON CHEMICAL ANALYSIS OF WATER SAMPLE

Source of Sample..... Boxanagar Higher Secondary School
Number of Sample..... 01 (one)
Date of Collection..... 10-07-2026
Date of Testing..... 13-07-2026

Sl. No.	Description of Test	Result	Remarks
01.	Physical Appearance	clear	
02.	Turbidity in NTU	0.61 NTU	
03.	Ph Value	7.62	
04.	Total Alkalinity in mg/L as CaCo ₃	96 mg/l	
05.	Total Hardness in mg/L as CaCo ₃	76 mg/l	
06.	Total Iron in mg/L as Fe	0.075 mg/l	
07.	Chloride in mg/L as Cl	20 mg/l	
08.	Residual Chlorine in mg/L	Nil	
09.	Phenolphthalein Alkalinity in mg/L as CaCo ₃	—	
10.	Calcium in mg/L as Ca	—	
11.	Magnesium in mg/L as Mg	—	
12.	Manganese mg/L as Mn	—	

Analysed by-

Quatter
13-7-2026.
(Smt. Rebeka Nath)
Sr. Research Assistant
PWD (DWS) Sub-Division, Sonamura
Sepahijala, Tripura.

Varified by-

13/7
Assistant Engineer
DWS Sub-Division, Sonamura
Sepahijala Tripura

GOVERNMENT OF TRIPURA
DWS LABORATORY AT TREATMENT PLANT AT SONAMURA
UNDER DWS SUB-DIVISION
SONAMURA, SEPAHIJALA TRIPURA

Dated, Sonamura, the 13th July, 2026

REPORT ON BACTROLOGICAL ANALYSIS OF WATER SAMPLE

Source of sample Boxanagar Higher secondary school
Number of sample 01 (one)
Date of Collection 10-07-2026
Date of receipt of sample 10-07-2026
Date of testing 13-07-2026

Sl. NO	DESCRIPTION OF TEST	RESULT	REMARKS
01.	Bactrological test	MPN/100	00

Analysed by-

Smt. Rebeka Nath
13-7-2026
(Smt. Rebeka Nath)
Sr. Research Assistant
PWD (DWS) Sub-Division, Sonamura
Sepahijala, Tripura.

Varified by-

Assistant Engineer
13/7/26
Assistant Engineer
DWS Sub-Division, Sonamura
Sepahijala Tripura